




	<p>Hvad er i kassen.</p> <p>Lagur behandlingsrør. Lagur elektronikstyring. Nøgle for montering.</p>
	<p>1. Installere behandlingsrør.</p> <p>Husk at installering altid skal være efter vandmåleren. Lagur Behandlingsrør kan monteres vertikalt samt horisontalt (og alt der i mellem) Gennemstrømningsretning valgfri.</p>
	<p>Sådan gør du.</p> <p>Under montering hold altid haknøgle i samme ende som du spænder.</p>
	
	<p>2. Tilslut styreenheden.</p> <p>Vigtigt montering af elektronikboks. Skal altid tilsluttes med jordstik. Den er standard monteret med et schukostik.</p>

NOTE
 Inner tube DIN 4404 (316L)
 In all editions



Dimensioner								
DN	X	Y	Z	Watt	Weight Kg.	Gevind	C	Shipping Weight Kg.
25	352	70	11,5	40W +-2	4,85	1" RG.	105	8,6
32	385	88,9	11,5	40W +-2	7,45	5/4" RG.	105	11,3
40	385	88,9	11,5	40W +-2	8,75	1½" RG.	105	12,6
50	385	114,3	11,5	40W +-2	9,40	2" RG.	105	13,4
65	385	114,3	11,5	40W +-2	10,25	2,5" RG.	105	14,3
80	400	158,0	11,5	40W +-2	18,50	3" RG.	105	20,7
100	400	158,0	11,5	40W +-2	17,60	4" RG.	105	19,8



Lagur ApS Attrupvej 4 8550 Ryomgård post@lagur.dk	Emne & sagsnr: Datablad -	Side 1 / 1
	Tegnings nr: Datablad-19062018	

CERTIFIKAT

CERTIFICATE



**GODKENDT
TIL DRILLEKVVAND**



Dette certifikat er udstedt i henhold til bekendtgørelse nr. 1007 af 29. juni 2016 om markedsføring og salg af byggevarer i kontakt med drikkevand. Certifikatet giver godkendelsesindehaveren rettighed til at markedsføre og sælge nedenstående byggevarer i Danmark og til at mærke byggevarer med "Godkendt til drikkevand"-mærkningen.

This certificate is issued according to Executive Order no. 1007 of 29 June 2016 on the placement on the market and sale of building components that come into contact with drinking water. The certificate gives the approval holder the rights to market and sell the following building component in Denmark and to mark the building component with the "Godkendt til drikkevand" marking.

GODKENDELSE NR. / APPROVAL NO.:

05/00003

UDSTEDT / DATE OF ISSUE:

16-10-2017

UDLØBER / EXPIRY DATE:

15-10-2022

GODKENDELSESINDEHAVER / APPROVAL HOLDER:

**Lagur ApS
Attrupvej 4
8550 Ryomgård
DK, Danmark**

BYGGEVARE / BUILDING COMPONENT:

Lagur Vandbehandler



BETINGELSER FOR GODKENDELSE:

De nærmere betingelser og vilkår for godkendelsen er fastsat i bekendtgørelse nr. 1007 af 29. juni 2016 om markedsføring og salg af byggevarer i kontakt med drikkevand. Endvidere henvises til godkendelsesbrev af 11-09-2017 om godkendelse af ovennævnte byggevarer i kontakt med drikkevand og eventuelle senere ændringer til godkendelsesbrevet fremsendt til godkendelsesindehaver. Markedsføring og salg af byggevarer efter nærværende godkendelse omfatter de versioner af byggevarer, der er opført i bilaget, og den variantproduktion, der er angivet i bilaget.

CONDITIONS OF APPROVAL:

The detailed terms and conditions of approval are laid down in Executive Order no. 1007 of 29 June 2016 on the placement on the market and sale of building components in contact with drinking water. See also the approval letter of 11-09-2017 on the approval of the above-mentioned building component in contact with drinking water, and any subsequent amendments to the approval letter submitted to the approval holder. Marketing and sale of the building component under this approval include the versions of the building component listed in the Annex and the "on-demand" production specified in the Annex.

CERTIFIKATET ER UdstEDT AF:

THE CERTIFICATE IS ISSUED BY:

Trafik-, Bygge- og Boligstyrelsen
Danish Transport, Construction
and Housing Authority
Edvard Thomsens Vej 14
2300 København S
Mail: GDV@tbst.dk
Web: www.tbst.dk

København, den 11-09-2017

Birgitte Lundblad
Kontorchef / Head of division